



City of Foley, AL

407 E. Laurel Avenue
Foley, AL 36535

Signature Copy

Resolution: 19-1314-RES

File Number: 19-0535

Enactment Number: 19-1314-RES

A Resolution Approving the Replacement of Fuel System Wiring

WHEREAS, The Public Works Department needs to replace the Fuel System wiring from the tanks to and into the Public Works building, and

WHEREAS, This is a requirement of ADEM, and it was included in the FY20 budget under the Capital Projects Plan for \$15,000.00 under Account# 400-1050-5100 Fuel Pump Building Improvements, and

WHEREAS, The total cost of the replacement is \$13,162.56 through Mike Hoffman's Equipment Service, Inc.

NOW THEREFORE BE IT RESOLVED that the City Council of the City of Foley, Alabama, as follows:

SECTION 1: Approves the wiring replacement for the fuel system for up to \$15,000 through Mike Hoffman's Equipment Service, Inc. to meet ADEM requirements under Account# 400-1050-5100 Fuel Pump Building Improvements, and amends the budget accordingly.

SECTION 2: This Resolution shall become effective immediately upon its adoption as required by law.

PASSED, APPROVED AND ADOPTED this 7th day of October 2019.



President's Signature

Date

10-7-19

Attest by City Clerk

Date

10-7-19

Mayor's Signature

Date

10/14/19

Deena Townsend

From: David Fillingham <david@mikehoffmans.com>
Sent: Wednesday, June 12, 2019 7:59 AM
To: 'Deena Townsend'
Subject: Wiring/Conduit - Option #2

Categories: Enviro, Darrell/Rick

Replace existing conduit for tank probes/sensor, hand dig trench for new conduit, pull new Belden wire and tie into the Veeder Root system. Labor/materials \$13,162.56

David Fillingham

Mike Hoffman's Equipment Service, Inc.

4109 Halls Mill Road

Mobile, Al. 36693

P. 251.666.8994

F. 251.661.9558

www.mikehoffmans.com

14-0535

Capital Project Worksheet

Directions:

Please complete all questions below and submit to Mike Thompson and Wayne Trawick for approval.
If this project is approved, you must complete the Pre-Project Worksheet and Budget forms.

Submitted by: Darrell Russell

Date Submitted: 09/30/2019

Is this purchase listed on the capital projects plan in the approved budget? Yes

What amount is approved in the plan for this project? \$15,000.00

In what year is this project shown to begin in the plan? 2020

Description of the project and why the project needs to be completed at this time.

Replace/Repair wiring from fuel pump to building. Replacement of existing conduit from fuel tanks to building for tank probes/sensor, hand dig trench for new conduit, pull new Beldin wire & tie into Veeder Root system per ADEM requirements

Can your job be performed without the completion of this project? Please explain below.

No, there have been too many alarms, so ADEM is requiring it.

Will not completing this project cause a public safety issue? Please explain below.

Yes, per ADEM & the Environmental Dept. It is an environmental issue.

Do you expect to come in, at, or under budget on this project? Please explain below.

We expect to come in a little below.

Is there a grant associated with this project? No

If so please list below the grant amount and the match required by the City.

Approval by City Administrator Mike Thompson 10/7/19
Signature and Date

Approval by Council President Wayne Trawick 10-7-19
Signature and Date