



Miriam Boone <mboone@cityoffoley.org>

Your request has been approved.

1 message

Jotform <noreply@jotform.com>
Reply-To: charrison@cityoffoley.org
To: mboone@cityoffoley.org

Wed, Jun 25, 2025 at 9:07 AM



Your request has been approved.

CAPITAL PURCHASE/PROJECT EXPENDITURE

Submitted by:	Miriam Boone
Date	06/25/2025
Department	CDD
Email	mboone@cityoffoley.org
Select item type	Capital Project
Capital item description	Exhaust Fan for Generator
Item Listed in Budget	Capital Project Plan
Will this capital item replace a current capital asset?	No
Is there a Grant associated with this capital item?	No

The approved current fiscal year budget shows the capital item expenditure is budgeted/planned in fiscal year(s) (1)

2025

and/or (2)

2025

.

Planned Project Amount (1)	\$40,750
Planned Project Amount (2)	\$0
Total in Budget Plan (1) (2)	\$40,750
Planned Grant Amount	\$0
Projected Cost/Expenditure	\$43,735
Excess/(Deficiency)	\$-2,985
Appropriated Amount	\$40,750
Approved Grant Amount	\$0
Projected Cost/Expenditure	\$43,735
Excess(Deficient) Funds	\$-2,985

Explanation for deficient funds or other important information:

This unit is larger and runs hotter, the existing vents do not offer enough air-flow. During the 2 hour test start it became apparent that a fan system is the only way to add the additional air-flow required to keep this unit from overheating causing an auto shutoff.

Request the following budget impact:

Transfer Budgeted Funds BETWEEN Categories

Budget transfer from **Department/Fund** to **Department/Fund**.

Email of the Director over the department budget is being transferred from:

mboone@cityoffoley.org

Budget Category transferring from:

Operational Budget

Budget Category transferring to:

Capital Budget

Transfer From Budget Detail:

Amount of Funds	Account Number	Account Name
-----------------	----------------	--------------

2985	10020306010	Building/Grounds Maintenance
------	-------------	---------------------------------

Transfer To Budget Detail:

Amount of Funds	Account Number	Account Name
2985	400-2030-5101	CDD Generator

Explanation for budget
appropriation and/or transfer:

This unit is larger and runs hotter, the existing vents do not offer enough air-flow. During the 2 hour test start it became apparent that a fan system is the only way to add the additional air-flow required to keep this unit from overheating causing an auto shutoff.

[ExhaustFan_quote.pdf](#)
[Fantech FADE 20-6 WHD Axial Fan.pdf](#)

3 attachments



Miriam-Boone-CDD.pdf
87K



ExhaustFan_quote.pdf
129K



Fantech FADE 20-6 WHD Axial Fan.pdf
548K