



Alabama Department of Environmental Management
adem.alabama.gov

1400 Coliseum Blvd. 36110-2400 ■ Post Office Box 301463
Montgomery, Alabama 36130-1463
(334) 271-7700 ■ FAX (334) 271-7950

OCT -7 2014

MAYOR JOHN KONIAR
CITY OF FOLEY
407 EAST LAUREL AVE
FOLEY AL 36536

RE: Compliance Evaluation Inspection

Expired No Exposure Certification /terminated ALG140074
Foley Municipal Airport
510 North Airport Blvd.
Foley, AL 36536
Baldwin County (003)

Dear Mayor Koniar:

The Department has completed a comprehensive evaluation of **Foley Municipal Airport**, in an effort to determine its compliance with applicable rules and provisions of the National Pollutant Discharge Elimination System (NPDES) and ADEM Admin Code r. 335-6-6. The Department observed the following:

- Ala. Code §22-22-9(i)(3) (2006 Replc. Vol.) requires that a permit be obtained prior to discharging any new or increased pollution into any water of the state. ADEM Administrative Code, Chapter 335-6-6-.03 (2) states that no person, required to apply for a storm water discharge permit by 40 CFR 122.26 (2000), shall discharge pollutants into waters of the state without first having applied for a valid NPDES permit, coverage under a valid General Permit, or coverage under a valid NPDES Registration. During the September 23, 2014 inspection, the Department observed an operational airport with petroleum storage exposed to storm water. Currently, the Foley Municipal Airport is not permitted under an NPDES Permit. General NPDES Permit ALG140074 was terminated at the request of the facility on July 8, 2003, and was replaced by a no exposure certification that expired on June 9, 2008.

Please be aware that petroleum storage and fueling areas that are associated with a maintenance shop are not excluded from NPDES permitting and if this area is exposed to storm water, the facility would not qualify for the no exposure exclusion.

Within 30 days of receipt of this letter, the facility should submit an ALG140000 Notice of Intent (NOI) with an application fee of \$1155; or if applicable, a completed No Exposure Certification form. The appropriate forms



and information regarding electronic permit application submittal can be found at http://www.adem.state.al.us/programs/water/_permitting.cnt. The submittal should be mailed to **Dodi Moseley** in the Department at the Montgomery address listed at the top of this letter.

The Department encourages you to voluntarily consider pollution prevention strategies to resolve these present and prevent potential future violations.

If you have questions regarding this matter, please contact Dodi Moseley by email at dbmoseley@adem.state.al.us or by phone at (334) 271-7725.

Sincerely,



Lee Warren, Chief
Industrial General Permit Section
Industrial/Municipal Branch
Water Division

File: CORS/4805

Encl(s): CEI Report

Pc: Lee Warren, ADEM, Industrial General Permit Section
Dodi Moseley, ADEM, Industrial General Permit Section
Mark Ornelas, ADEM, Field Operations Division, Mobile



Alabama Department of Environmental Management
NPDES INSPECTION REPORT


Company/Operator/Permittee: Foley Municipal Airport		FID 3030	Phone Number: (251) 943-1545	
Mailing Address: 407 East Laurel Avenue	City Foley	State AL	Zip Code 36536	
Responsible Official/Operator Name: John Koniar, Mayor, City Of Foley				

Facility Name: Foley Municipal Airport	NPDES Permit #: ALG140074	Permit Effect Date: 10/09/2002	Inspection Entry Date & Time: 9/23/2014 1:30 PM	County: Baldwin
Activity Description Transportation	NMS Inspection #: 46652	Permit Expire Date: 09/30/2007	Inspection Exit Date & Time: 9/23/2014 3:00 PM	Report Complete Date: 9/26/2014
Inspection Type: (X) CEI () CSI () PAI Routine (X) Complaint () Photos Taken (X) Samples Collected ()				

Township, Range, Section: T0S R0E S1
Physical Address/Location Description (include nearest city): 510 North Airport Blvd., Foley, AL

Entrance Latitude & Longitude: 30.428825, -87.704211
Discharge Point(s) Latitude & Longitude: *See Notes
Receiving Water(s): Magnolia River
Weather Conditions: Clear

Summary: N/A

Name(s) of On-site Representative(s) and Phone Numbers: Rachel Keith, Airport Manager, City of Foley (251) 943-1545 Leslie Gahagan, Environmental Manager, City of Foley (251) 952-4011		
Name of Inspector: Steven Summersell	Signature of Inspector: 	Date: 9/26/2014
Name of Reviewing Supervisor: Mark Ornelas	Signature of Reviewing Supervisor: 	Date: 9-26-2014

FOD Office: Mobile

NPDES INDUSTRIAL STORMWATER INSPECTION REPORT

FACILITY NAME: Foley Municipal Airport

PERMIT NUMBER: ALG140074

I. RECORDS

A. Copy of Permit Available	X N/A	YES	NO	Comment # 1
B. Discharge Monitoring Reports (DMRs) Available	X N/A	YES	NO	Comment #
DMRs Retained for 3 Years	X N/A	YES	NO	Comment #
C. Laboratory Records Available	X N/A	YES	NO	Comment #
Laboratory Records Retained for 3 Years	X N/A	YES	NO	Comment #
D. Commercial Lab Used for Reported Analyses	X N/A	YES	NO	Comment #
Name:	Location:			
E. Adequate Records Maintained of:				
1. Sample Date, Time and Location	X N/A	YES	NO	Comment #
2. Analyses Date and Time	X N/A	YES	NO	Comment #
3. Analytical Methods	X N/A	YES	NO	Comment #
4. Standard Methods/EPA Approved Analytical Method	X N/A	YES	NO	Comment #
5. Analyst	X N/A	YES	NO	Comment #
6. Lab Equipment Calibration and Maintenance	X N/A	YES	NO	Comment #
7. Rainfall Data	X N/A	YES	NO	Comment #
F. Correct Name and Mailing Address of Permittee	X N/A	YES	NO	Comment #

II. POLLUTION PREVENTION PRACTICES/PLANS

A. Best Management Practices (BMP) Plan Available	X N/A	YES	NO	Comment # 2
Last Update to BMP Plan:				
B. BMP Measures Appear Adequate, If no provide	X N/A	YES	NO	Comment #
C. BMP Training Records Available	X N/A	YES	NO	Comment #
D. BMP Inspection Records Available	X N/A	YES	NO	Comment #
Inspection Records Retained for 3 Years	X N/A	YES	NO	Comment #
E. Spill Prevention Control and Countermeasures (SPCC) Plan Available	X N/A	YES	NO	Comment # *See 2
Last Update to SPCC: *April 29, 2014				
List Tanks and Capacities in Comment Section				Comment # 3
F. Pollution Prevention (P2)/Source Reduction Plan and/or P2 Practices	X N/A	YES	NO	Comment #
G. All Discharges Appear to be properly Permitted	X N/A	YES	NO	Comment # 4
H. Adequate Containment for Products/Byproducts and Waste Materials	N/A	X YES	NO	Comment # 5

III. MONITORING INFORMATION

A. Flow Measurement				
Method of measurement on Non-Stormwater Outfalls:	Instantaneous	Weir	Other	
B. Sampling				
1. Location(s) Adequate	X N/A	YES	NO	Comment #
2. Sample Type(s) Agree with Permit	X N/A	YES	NO	Comment #
3. Preservation Techniques Agree with 40 CFR 136	X N/A	YES	NO	Comment #
4. Sample Holding Times Agree with EPA Guidance	X N/A	YES	NO	Comment #
5. Monitoring and Analyses Performed More Frequently Than Required	X N/A	YES	NO	Comment #
6. If Yes to 5, Results are Reported in Permittee's Self Monitoring Report	N/A	YES	NO	Comment #
7. Stormwater Samples Collected in Accordance with Permit Requirements	X N/A	YES	NO	Comment #

N/A – Not Applicable

NPDES INDUSTRIAL STORMWATER INSPECTION REPORT

IV. EFFLUENT/RECEIVING WATER VISUAL OBSERVATIONS			
Outfall(s) have Oil Sheen	YES	X NO	Comment #
Outfall(s) have Visible Foam	YES	X NO	Comment #
Outfall(s) have Visible Floating Solids	YES	X NO	Comment #

V. COMMENTS		
Comment No.		Photograph No.
1	The permit was terminated effective July 8, 2003. A No Exposure Certification was received By the Department on June 9, 2003. However, the facility has not re-certified.	
2	Recently, the facility removed an underground storage fuel tank (UST) and installed an above ground fuel storage tank. The facility has a SPCC Plan dated April 29, 2014 that covers the storage tank and fueling area.	
3	One 10,000 gallon double wall above ground aviation fuel storage tank, one 280 gallon portable aviation fuel storage tank, one 55 gallon drum bulk motor oil, and approximately two 55 gallon drums of used motor oil contained on a concrete slab.	
4	The facility has several outfalls that appear to drain to the Magnolia River. The fueling area and maintenance shop appear to discharge into a stormwater conveyance located along the northwest corner of the airport runway.	
	Storage buildings and parking areas appear to discharge via stormwater conveyances along the western portion of the facility and into Magnolia River.	
	Also, the Northern portion of the facility's airfield appears to drain into a stormwater conveyance via drains located between the runway and taxiway. The stormwater conveyance flows northeast along a berm to a primary flow device (rectangular weir with end contractions), just prior to discharge into the Magnolia River.	
	The southern portion of the airfield appears to discharge into a stormwater conveyance along the western portion of the facility. It should be noted that stormwater from off site appears to enter the facility's southern stormwater conveyance and discharges into the stormwater conveyance on the western portion of the facility.	
	It should also be noted that along the eastern portion of the facility, a stormwater conveyance from Peachtree Street (the "Peachtree Street Outfall"), enters a stormwater conveyance located along the northeast portion of the runway and discharges into the primary flow device prior to discharge into the Magnolia River.	
5	Waste used motor oil is collected by Heritage-Crystal Clean, LLC. All maintenance work is performed in an enclosed area. No staining was observed on pervious or impervious surfaces. The facility maintains a spill response kit.	
	*See Inspection Photos.	

VI. SAMPLE RESULTS

N/A

LANCE R. LEFLEUR
DIRECTOR



ROBERT J. BENTLEY
GOVERNOR

Alabama Department of Environmental Management
adem.alabama.gov

1400 Coliseum Blvd. 36110-2400 ■ Post Office Box 301463
Montgomery, Alabama 36130-1463
(334) 271-7700 ■ FAX (334) 271-7950

September 24, 2014

John Koniar, Mayor, City Of Foley
Foley Municipal Airport
407 East Laurel Avenue
Foley, Alabama 36536

RE: Facility Inspection

NPDES Permit # ALG140074
FID 3030
Inspected 9/23/2014

Dear Sir/Madam:

Enclosed is a copy of an inspection report for the above referenced facility. A copy of the inspection report has been transmitted to the Department's Water Division for a compliance determination and any follow-up as appropriate.

Should you have any questions regarding permitting, compliance, enforcement, or any follow-up action you should take to address any deficiencies noted, please contact your ADEM permit staff contact or the Water Division in Montgomery at H2Omail@adem.state.al.us or by phone at (334) 271-7799.

Should you have any questions regarding observations noted during the inspection, please contact me by email at ssummersell@adem.state.al.us or by phone at (251) 432-6533.

Sincerely,

A handwritten signature in black ink, appearing to read "S. Summersell", is written over a horizontal line.

Steven Summersell
Field Operations Division

File: INSPR/4805

ecopy: Rachel Keith, Airport Manager, City of Foley
Leslie Gahagan, Environmental Manager, City of Foley
Water Division

Enclosure: Inspection Report
Inspection Photos

Birmingham Branch
110 Vulcan Road
Birmingham, AL 35209-4702
(205) 942-6168
(205) 941-1603 (FAX)

Decatur Branch
2715 Sandlin Road, S. W.
Decatur, AL 35603-1333
(256) 353-1713
(256) 340-9359 (FAX)



Mobile Branch
2204 Perimeter Road
Mobile, AL 36615-1131
(251) 450-3400
(251) 479-2593 (FAX)

Mobile-Coastal
4171 Commanders Drive
Mobile, AL 36615-1421
(251) 432-6533
(251) 432-6598 (FAX)


Foley Municipal Airport

ALG140074


Baldwin County

S. Summersell

9/23/2014



Northern portion of facility.



Southern portion of facility.



Maintenance Shop.



Above ground fuel tank, portable tank, and spill response kit.



Portable fuel tank.



Bulk and used oil storage area.



Storage building and parking area drainage along western portion of facility.