



Memo

To: Randy Kurtts, City of Foley
From: Jim Jurkiewicz, E-J Builders, Inc.
Date: April 4, 2019
Re: Foley Justice Center Renovations

You have requested changes in the work which will result in change of work scope and additional cost as follows:

- Furr out masonry walls at south wall of court room around door masonry surround accent trim on 2 door locations. Install and finish 5/8" moisture resistant gypsum board on walls. Paint one pair of H.M. doors and frame inside and out. Paint new gypsum board walls and existing overhead furr down and masonry surrounds.
- Provide fire inspector suggested upgrades to 2 exit lights in court room to add emergency LED lighting. Add 1 wall mounted LED emergency light at south wall of court room. Add 2 emergency ceiling mounted LED lights in magistrate office area.

The cost for these changes is \$1,734.54.

Thanks