

GeoCon Engineering and Materials Testing, Inc.
22885 McAuliffe Drive
Robertsdale, Alabama 36567

FIELD OBSERVATION REPORT

Project: Woerner Properties
Location: Foley, AL

Job No.: JG 993-18
Date: 10/15/2019

Architect: N/A
General Contractor: N/A
Site Work Subcontractor: Ammons & Blackmon
Weather: Clear

Observations:

Observed the subgrade soils along the south access drive, full length, both lanes. Soils were loose and yielding to a depth of 3 1/2 feet below the existing ground surface. Recommended to the contractor to undercut the south access drive by a depth of 3 1/2 feet and replace with a clean select sand fill.

Field Representative: Will Sharp